

WALL ASSEMBLY  
ZIP SYSTEM® WALL SHEATHING  
WOOD OR LT. GA. METAL STUDS


1/8-INCH GAP RECOMMENDED AT  
PANEL EDGES UNLESS  
OTHERWISE PROVIDED BY  
MACHINED PROFILED EDGES

INSTALL ZIP SYSTEM® TAPE OR  
ADHESIVE BACKED FLASHING (MUST  
MEET AC148) IN SEQUENCE FROM  
BOTTOM, SIDES, THEN TOP TO  
ENSURE SHINGLE LAP OF ADHESIVE  
BACKED FLASHING

ZIP SYSTEM® TAPE (INSTALLED  
OVER ALL JOINTS IN ZIP SYSTEM®  
WALL SHEATHING).

OVERLAP TAPE A MINIMUM OF  
1-INCH AT ALL T-JOINTS

USE FLANGED VENT HOODS



DRAWING NOT TO SCALE